

# VERIFICATION OF COMPLIANCE

No.: LVD SHES2310019891MI

Applicant: Acrel Co., Ltd.  
No.253, Yulv Road, Jiading, Shanghai, China

Manufacturer: Same as applicant

Product Name: Controlled Prepayment Electricity Meter

Product Description: Support the measurement function of single power grid to measure voltage, current, power, frequency and other electrical parameters

Model No.: DDSY1352, ADL100-EY

Rating: 220VAC, 10VA, 50 Hz; 10(60)A

Protection against Electric Shock: Class II

Additional Information (if any): None

Sufficient samples of the product have been tested and found to be in conformity with

Test Standard: EN 61010-1:2010/A1:2019  
EN IEC 61010-2-030:2021/A11:2021

as shown in the  
Test Report Number(s): SHES231001989101

This Verification of Compliance has been granted to the applicant based on the results of tests, performed by Laboratory of SGS-CSTC Standards Technical Services Co., Ltd. on sample of the above-mentioned product in accordance with the provisions of the relevant harmonized standards under the Low Voltage Directive 2014/35/EU. The CE marking as shown below can be affixed, under the responsibility of the manufacturer, after completion of an EC Declaration of Conformity and compliance with all relevant EC Directives. The affixing of the CE marking presumes in addition that the conditions in annexes III and IV of the Directive are fulfilled.



Andrew Zhai  
Technical Manager  
SGS-CSTC

2024-03-19



Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services which can be accessible at <https://www.sgs.com/en/terms-and-conditions>.  
Member of SGS Group (Société Générale de Surveillance)